



1590 Reed Road
Pennington, NJ 08534

Tel: (609) 737-3477
Fax: (609) 737-3052
www.njal.com

Sample Information

NJAL Lab ID # 8136	Otterlei Residence 165 Lindbergh Road Hopewell, NJ 08525 Lot 1, Block 36 East Amwell Township Hunterdon County, NJ Kitchen Tap	Date Sampled: 12/11/03 Time Sampled: 2:52 PM Sampled by: ED/NJAL Date Received: 12/11/03
--------------------	--	---

Parameter	Result	Detection Limit	Units	Maximum Contaminant Level	Method Code
Total Coliforms	290	1	colonies/100ml	0	SM 9222B
E. Coli	ND	1	colonies/100ml	0	SM 9222B

ND-Not Detected

Coli Date Analyzed: 12/11/03
Coli Time Analyzed: 1600 hrs.

This sample exceeds the NJDEP MCL criteria for Total Coliforms.

NJDEP Laboratory ID # 11005


George Latham
Laboratory Director

12/11/03
Date

New Jersey Analytical Laboratories

NJAL Lab ID	8136	Date Analyzed	12/12/03
Analyte	Concentration (ug/L)	Method Detection (ug/l)	Qualifiers
1,1-dichloropropanone	nd	0.8	
trans-1,3-dichloropropene	nd	0.1	
toluene	nd	0.50	
ethyl methacrylate	nd	0.4	
cis-1,3-dichloropropene	nd	0.2	
2-hexanone	nd	0.9	
1,1,2-trichloroethane	nd	0.5	
1,3-dichloropropane	nd	0.3	
tetrachloroethene	→ 5.1	0.1	
dibromochloromethane	nd	0.3	
1,2-dibromoethane	nd	0.1	
chlorobenzene	nd	0.1	
ethylbenzene	nd	0.1	
1,1,1,2-tetrachloroethane	nd	0.1	
m/p xylene	nd	0.1	
o-xylene	nd	0.1	
styrene	nd	0.1	
isopropyl benzene	nd	0.1	
bromoform	nd	0.3	
1,1,2,2-tetrachloroethane	nd	0.3	
1,2,3-trichloropropane	nd	0.7	
n-propyl benzene	nd	0.1	
trans-1,4-dichloro-2-butene	nd	0.5	
bromobenzene	nd	0.2	
1,3,5-trimethyl benzene	nd	0.1	
2-chlorotoluene	nd	0.1	
4-chlorotoluene	nd	0.1	
tert-butylbenzene	nd	0.1	
1,2,4-trimethylbenzene	nd	0.2	
pentachloroethane	nd	0.1	
sec-butylbenzene	nd	0.2	
p-isopropyltoluene	nd	0.1	
1,3-dichlorobenzene	nd	0.1	
1,2-dichlorobenzene	nd	0.2	
n-butyl benzene	nd	0.1	
1,4-dichlorobenzene	nd	0.1	
1,2-dibromo-3-chloropropane	nd	0.9	
hexachloroethane	nd	0.1	
nitrobenzene	nd	1.4	
1,2,4-trichlorobenzene	nd	0.3	
hexachlorobutadiene	nd	0.1	
naphthalene	nd	0.4	
1,2,3-trichlorobenzene	nd	0.3	

NJDEP Cert#11005


 Allen F. Thomas
12-23-03
Date

Precision testing for a cleaner environment.



1590 Reed Road
Pennington, NJ 08534

Tel: (609) 737-3477
Fax: (609) 737-3052
www.njal.com

Sample Information		Analysis Information	
NJAL Lab ID	8136	Date Analyzed	12/12/03
Client ID	165 Lindberg Road	Time Analyzed	21:24
Date Received	12/11/03	Dilution Factor	1
Time Sampled	14:52	Analysis Method	EPA 524
Collected by	ED/NJAL	Analyst	A. Thomas

Volatile Organics (Method 524.4)

Analyte	Concentration (ug/L)	Method Detection (ug/l)	Qualifiers
Dichlorodifluoromethane	nd	0.1	
chloromethane	nd	0.4	
vinyl chloride	nd	0.1	
bromomethane	nd	0.1	
chloroethane	nd	0.1	
diethyl ether	nd	0.1	
methyl iodide	nd	0.1	
allyl chloride	nd	0.1	
carbon disulfide	nd	0.1	
Tertiary Butyl Alcohol	nd	0.8	
acrylonitrile	nd	0.7	
MTBE	nd	0.3	
Methylethyl Ketone (MEK)	nd	2.5	
Acetone	nd	2.2	
Trichlorofluoromethane	nd	0.1	
1,1-dichloroethene	nd	0.1	
methylene chloride	nd	0.2	
trans-1,2-dichloroethene	nd	0.1	
1,1-dichloroethane	nd	0.1	
propionitrile	nd	0.9	
2,2-dichloropropane	nd	0.3	
methacrylonitrile	nd	0.8	
methyl acrylate	nd	0.2	
chloroform	nd	0.2	
THF	nd	1.0	
bromochloromethane	nd	0.2	
1,1,1-trichloroethane	nd	0.1	
1-chlorobutane	nd	0.1	
1,1-dichloropropene	nd	0.1	
carbon tetrachloride	nd	0.1	
1,2-dichloroethane	nd	0.1	
benzene	nd	0.1	
trichloroethene	nd	0.2	
1,2-dichloropropane	nd	0.1	
methylmethacrylate	nd	0.7	
chloroacetonitrile	nd	0.6	
dibromomethane	nd	0.1	
2-chlorovinyl ether	nd	0.1	
MIBK	nd	1.1	
Cis Dichloroethene	nd	0.1	
bromodichloromethane	nd	0.2	

Precision testing for a cleaner environment.

To: Lorie - Hill Environmental
(also the PH was tested
at ~ 6.1)
System installed.

3M Aberdeen

Fax

To: Les - Stothoff From: Leigh Otterlei
Fax: 9108-782-9528 Pages: 2
Phone: Date: 2/13/2004
Re: CC:

Urgent For Review Please Comment Please Reply Please Recycle

● Comments:

Please find following test results for water tests done on 165 Lindbergh Road in East Amwell (Mailing address Hopewell). There are confirming tests done for the Coliform and the Tetrachlorethane, but not for Ph. I will need a quote ASAP for a system that will treat for all three of these conditions.

Thanks!

Leigh Otterlei

605-229-5002 x 1114 (work)

605-225-0802 (home)